

NO.	SEWER NOTES
1.	ALL LATERALS AND MAINS SHALL BE TESTED AND TELEVISED AFTER CONSTRUCTION OF ALL OTHER UTILITIES AS SPECIFIED IN WAS SECTION 15043 OF THE STANDARD SPECIFICATIONS.
2.	ALL FORCE MAINS SHALL BE CONSTRUCTED WITH A 36 INCH MINIMUM COVER. ALL GRAVITY MAINS SHALL BE CONSTRUCTED WITH AN INVERT DEPTH OF 7.5 MINIMUM FEET, UNLESS OTHERWISE SHOWN APPROVED ON RMWD APPROVED PLANS.
3.	ALL LOTS SHALL BE SERVED BY PVC LATERALS SET AT MINIMUM GRADE OF 2.0% AND AN INVERT DEPTH OF 5.5 MINIMUM FEET AT PROPERTY LINE, UNLESS OTHERWISE APPROVED BY RMWD. ALL SEWER LATERALS SHALL BE INSTALLED PER WAS DRAWINGS SS-01 AND SS-02.
4.	THE CONTRACTOR MUST SECURE APPROVAL FROM THE RMWD INSPECTOR PRIOR TO BACKFILLING OVER ANY SEWER MAIN, LATERALS, OR "Y"s.
5.	MANHOLES ARE TO BE CONSTRUCTED PER WAS STANDARD DRAWING SM-01 OR SM-02.
6.	ALL END OF PIPE MANHOLES WILL BE BUILT WITH AN UPSTREAM 5 FOOT STUB OUT AND PLUGGED FOR FUTURE CONNECTIONS.
7.	MANHOLES TO HAVE WATER TIGHT JOINTS PER STANDARD WAS DRAWING SM-05.
8.	ALL SEWER MAINS ARE TO BE PVC WITH A MINIMUM 8 INCH DIAMETER UNLESS APPROVED BY THE DISTRICT ENGINEER.
9.	MANHOLES TO BE VACUUM TESTED PRIOR TO ACCEPTANCE IN ACCORDANCE WITH STANDARD WAS SECTION 03461.
10.	CONTRACTOR RESPONSIBLE FOR ANY SEWAGE SPILLS.
11.	CONTRACTOR IS RESPONSIBLE FOR ANY BY-PASS LINES AND BY-PASS PUMPING OF SEWER IF REQUIRED DURING CONSTRUCTION. PROPOSED BY-PASS SHALL BE SUBMITTED TO RMWD FOR REVIEW AND APPROVAL PRIOR TO INSTALLATION.